

May 01, 2024

TOWN OF KILLINGLY
UNDERGROUND STORAGE TANK
REMOVAL and DEMOLITION

ADDENDUM NO. 1

Questions

Can you confirm whether Base Bid #1 and Base Bid #2 include:

1. Assessment at closure in general accordance with the CT DEEP Sampling and Analytical Methods for Underground Storage Tank Closure, at <https://portal.ct.gov/deep/underground-storage-tanks/ust-closure-sampling-and-analytical-methods>
2. Preparation of a closure report by a licensed environmental professional,
3. 30-day advance notification to the DEEP of pending UST closure,
4. Notification to the DEEP after UST closure,
5. Town Fire Marshal permit?

Answers

1. Yes. Compliance with CT DEEP UST requirements is required.
2. The closure report does not need to be performed by a LEP.
3. Yes. A 30-day notification to DEEP is required. The contract start time can be adjusted to allow for the notification.
4. Yes. Notification to CT DEEP using EZFile is required. Please refer to regulatory compliance in the RFP.
5. Yes. Please see Regulatory Compliance in the RFP.

The questions and responses in Addendum No.1 are available on the Town of Killingly Website <https://www.killingly.org/finance/pages/bids-and-rfps> and the CTSource Website <https://portal.ct.gov/DAS/CTSource/Login> :