



# Town of Killingly

Engineering Department  
172 Main Street, Killingly, CT 06239  
Phone 860-779-5360 Fax 860-779-5326

## MEMORANDUM

**TO:** Normand Thibeault Jr. P.E. Killingly Engineering Associates 114 Westcott Road, P.O. Box 421, Killingly Ct 06241, via email at nthibeault@killinglyea.com

**FROM:** David Capacchione, Town Engineer; Gary Martin, Assistant Town Engineer

**DATE:** December 21, 2020

**RE:** 1496 Hartford Pike, Killingly, Ct

**CC:** Ann Marie Aubrey Director of Planning and Development, Elsie Bisset, Director Economic Development, Jonathan Blake, Planner I, & Zoning Enforcement Officer; file \

The Town Engineering department has received the following information for the subject project at our office through May 14, 2020:

Item 1: Set of two (2) drawings entitled "Improvement Location Survey Septic System Design Plan" Plan Prepared for Richard R. O'Keefe 1496 Hartford Pike (Route 101) Killingly, Connecticut, prepared by Killingly Engineering Associates 114 Westcott Road, P.O. Box 421 Killingly Connecticut 06241 and dated 11/17/2020.

We have reviewed the item listed above and have the following comments pursuant to the Inland Wetland & Planning and Zoning Commissions:

### Comments:

1. Please provide a CDOT driveway permit and include their driveway detail on the plans.
2. I am concerned about the proximity to both wetlands and the 100-year flood elevation. Please demonstrate there will be no adverse impacts to the wetlands or the proposed development.
3. Please demonstrate adequate sightline.

Please contact the Town of Killingly Engineering Office at (860) 779-5360 if you have any questions or need additional information. We will be happy to meet with you to discuss the above referenced project.